



## KEYED NOTES

- 1 CONNECT SENSING LINE TO A STRAIGHT SECTION OF PIPING, MINIMUM 10 PIPE DIA'S OR 24", WHICHEVER IS GREATER.
- 2 LOCATE TEST TEE WITH 1/2" VALVE AND PLUG IN BOTTOM OF CONDENSATE LINE.
- 3 3/4" BYPASS FOR INITIAL WARM-UP.

# STEAM PRV STATION DETAIL

SCALE: NONE

## NOTE:

1 SEE SHEET 4 FOR DESIGN NOTES.

NO.	DATE	CLASS REV	REVISIONS	APP
FACILITY ENGINEERING MANUAL				
STEAM PRV STATION				
SINGLE STAGE				
APPROVED: DISCIPLINE POC DANNY NGUYEN			DATE: 6-28-99	
Los Alamos			Los Alamos National Laboratory Los Alamos, New Mexico 87545	1 OF 4
CLASSIFICATION: U		REVIEWER: DANNY NGUYEN		DATE:
REFERENCE DOCUMENT:		DRAWING NUMBER:		REV
CHAPTER 6		ST6202		